



SINGLE SURVEY



Property

1C Laing Street,
Kirkwall,
KW15 1NW

Prepared for



Date of Inspection

22 September 2026

SECTION 1 — INFORMATION AND SCOPE OF INSPECTION

This section tells you about the type, accommodation, neighbourhood, age and construction of the property. It also tells you about the extent of the inspection and highlights anything that the surveyor could not inspect.

All references to visual inspection refer to an inspection from within the property without the need to move any obstructions and externally from ground level within the site and adjoining public areas. Any references to left or right are taken facing the front of the property.

The inspection is carried out without causing damage to the building or its contents and without endangering the occupiers or the surveyor. Heavy furniture, stored items and insulation are not moved. Unless identified in the report the surveyor will assume that no harmful or hazardous materials or techniques have been used in the construction. The presence or possible consequences of any site contamination will not be researched.

Services such as TV/cable connection, internet connection, swimming pools and other leisure facilities etc. were not inspected or reported on.


Description	Mid-floor, one-bedroom flat within a traditional stone-built tenement.
Neighbourhood	The property lies within Kirkwall town centre, on the corner of Albert Street and Laing Street.
Accommodation	Hallway, sitting room, bedroom, kitchen, bathroom.
Age	Circa 225 years (built circa 1800).
Chimney stacks	<i>Visually inspected with the aid of binoculars where appropriate.</i> A large chimney on the gable wallhead carries five clay chimney pots, each capped with a clay ventilator cap. The stack has been harled and has a cast concrete chimney head and soakers.

Roofing	<i>Sloping roofs were visually inspected with the aid of binoculars where appropriate. Roof spaces were visually inspected and were entered where there was safe and reasonable access, normally defined as being from a 3m ladder within the property. If this is not possible, then physical access to the roof space may be taken by other means if the Surveyor deems it safe and reasonable to do so.</i> Welsh slate roof. No slipped slates were seen over the subject flat.
Rainwater fittings	<i>Visually inspected with the aid of binoculars where appropriate.</i> Plastic gutters to the rear elevation. Cast iron gutters and downpipe to the front (Albert Street) elevation.
Main walls	<i>Visually inspected with the aid of binoculars where appropriate. Foundations and concealed parts were not exposed or inspected.</i> Random rubble masonry walls with cast concrete skews at the wallhead. Exposed semi-dressed stone to the front (Albert Street) elevation, cement pointed. Rear elevation dashed.
Windows, external doors and joinery	<i>External doors were opened and closed where keys were available. Random windows were opened and closed where possible. Doors and windows were not forced open.</i> Timber sash and case windows throughout, double glazed.
External decorations	<i>Visually inspected.</i> External joinery is painted timber.
Conservatories and porches	<i>Visually inspected.</i> Not applicable.
Communal areas	<i>Visually inspected.</i> Shared entrance and common stair serving the building. Communal entrance door is 70cm wide. The electric meter for the flat is located in a cupboard within the common stair.
Garages and permanent outbuildings	<i>Visually inspected.</i> A shared brick built outbuilding is positioned at the rear of the common yard..
Outside areas and boundaries	<i>Visually inspected.</i> Not applicable — flatted dwelling with no private outside area.

Ceilings	<i>Visually inspected from floor level.</i> Plasterboard ceilings in the bedroom and kitchen.
Internal walls	<i>Visually inspected from floor level. Using a moisture meter, walls were randomly tested for dampness where considered appropriate.</i> Internal partition walls are lath and plaster. External walls are strapped and lined with plasterboard.
Floors	<i>Surfaces of exposed floors were visually inspected. No carpets or floor coverings were lifted. Sub-floor areas were inspected only to the extent visible from a readily accessible and unfixed hatch by way of an inverted "head and shoulders" inspection at the access point.</i> Fitted floor coverings throughout — close examination of floor surfaces was not possible.
Internal joinery and kitchen fittings	<i>Built-in cupboards were looked into but no stored items were moved. Kitchen units were visually inspected excluding appliances.</i> Moulded softwood skirtings and facings; basic fitted units in kitchen.
Chimney breasts and fireplaces	<i>Visually inspected. No testing of the flues or fittings was carried out.</i> The fireplace in the sitting room has been boxed in behind plasterboard — no access for inspection.
Internal decoration	<i>Visually inspected.</i> Lining paper and emulsion decoration throughout. Skirtings and facings gloss painted in the sitting room and bedroom.
Cellars	<i>Visually inspected.</i> None.
Electricity	<i>Accessible parts of the wiring were visually inspected without removing fittings. No tests whatsoever were carried out to the system or appliances. Visual inspection does not assess any services to make sure they work properly and efficiently and meet modern standards. If any services are turned off, the surveyor will state that in the report and will not turn them on.</i> Mains electricity connected. LED lighting throughout, except fluorescent tube lighting in the kitchen. Electric meter located in a cupboard in the common stair area, not within the flat.
Gas	<i>Visually inspected.</i> None.

Water, plumbing and bathroom fittings	<i>Visual inspection of the accessible pipework, water tanks, cylinders and fittings without removing any insulation. No tests whatsoever were carried out to the system or appliances.</i> Mains water connected. Standard sanitaryware installed.
Heating and hot water	<i>Accessible parts of the system were visually inspected apart from communal systems, which were not inspected. No tests whatsoever were carried out to the system or appliances.</i> No central heating. Space heating by night storage heater in the sitting room and bedroom, and an electric blow heater in the bathroom. Domestic hot water from an immersion heater in a hot water cylinder housed in a kitchen cupboard.
Drainage	<i>Drainage covers etc were not lifted. Neither drains nor drainage systems were tested.</i> Connected to mains drainage. Soil pipe to the rear elevation from the bathroom.
Fire, smoke and burglar alarms	<i>Visually inspected. No tests whatsoever were carried out to the system or appliances.</i> <i>IMPORTANT NOTE: Fire Safety Legislation effective from February 2022 requires a smoke alarm to be installed in the room most frequently used for living purposes and in every circulation space on each floor. A heat detecting alarm must be installed in every kitchen area and all smoke and heat alarms must be ceiling mounted and interlinked. Where there is a carbon-fuelled appliance e.g. central heating boiler, open fire, wood burning stove etc, a carbon monoxide detector is also required. The purchaser(s) should appraise themselves of the requirements of this legislation and engage with appropriately accredited contractors to ensure compliance.</i> Wired smoke detectors in the hallway and sitting room, heat detector in the kitchen.
Any additional limits to inspection	The fireplace in the sitting room is boxed in behind plasterboard and could not be inspected. Floor coverings prevented close examination of floor surfaces throughout. No access to roof void.

Sectional diagram showing elements of a typical house



SECTION 2 — CONDITION OF PROPERTY

This section identifies problems and tells you about the urgency of any repairs by using one of three categories.

1	Category 1 — No immediate action or repair is needed.
2	Category 2 — Repair or replacement requiring significant expenditure.
3	Category 3 — Urgent repairs or replacement are needed now.
n/a	Not applicable — this element is not present at the property.

STRUCTURAL MOVEMENT	Repair Category: 1
No evidence of structural movement was noted at the time of inspection.	

DAMPNESS, ROT AND INFESTATION	Repair Category: 1
No dampness was detected at the time of inspection.	

CHIMNEY STACKS	Repair Category: 1
Chimney stack harled, with cast concrete chimney head and soakers, five clay pots each capped. No defects noted.	

ROOFING INCLUDING ROOF SPACE	Repair Category: 1
Welsh slate roof, generally old. No slipped slates seen over the subject flat. No access to roof void.	
RAINWATER FITTINGS	Repair Category: 1
Front (Albert Street) cast iron gutters and downpipe found full of vegetation. Recommend cleared as routine maintenance.	
MAIN WALLS	Repair Category: 1
No defects noted to the masonry walls at the time of inspection.	
WINDOWS, EXTERNAL DOORS AND JOINERY	Repair Category: 1
Timber sash and case windows, double glazed. No defects noted.	
EXTERNAL DECORATIONS	Repair Category: 1
Paint on front gutters tired. Where open to examination external decoration of windows was satisfactory.	
CONSERVATORIES AND PORCHES	Repair Category: n/a
Not applicable.	
COMMUNAL AREAS	Repair Category: 1
Entrance door from communal area is only 70cm wide — unusually narrow. No other defects noted to communal areas at the time of inspection.	

GARAGES AND PERMANENT OUTBUILDINGS	Repair Category: 1
Adequate.	

OUTSIDE AREAS AND BOUNDARIES	Repair Category: n/a
Not applicable.	

CEILINGS	Repair Category: 1
Decoration untidy at the wall/ceiling junction in the bedroom, paper carried onto the ceiling.	

INTERNAL WALLS	Repair Category: 1
Satisfactory.	

FLOORS INCLUDING SUB-FLOORS	Repair Category: 1
Fitted floor coverings throughout — close examination of floor surfaces was not possible.	

INTERNAL JOINERY AND KITCHEN FITTINGS	Repair Category: 1
Satisfactory.	

CHIMNEY BREASTS AND FIREPLACES	Repair Category: n/a
Fireplace boxed in behind plasterboard, not inspected.	

INTERNAL DECORATION	Repair Category: 2
Decoration generally satisfactory, though untidy at the wall/ceiling junction in the bathroom due to overpainting.	

CELLARS	Repair Category: n/a
None.	

ELECTRICITY	Repair Category: 1
The electrical installation was not tested. No defects were noted at the time of inspection. It is recommended that the installation is checked by a suitably qualified contractor.	

GAS	Repair Category: n/a
None.	

WATER, PLUMBING AND BATHROOM FITTINGS	Repair Category: 1
No defects noted at the time of inspection.	

HEATING AND HOT WATER	Repair Category: 1
No defects noted to the storage heaters or blow heater at the time of inspection. It is recommended that the system be checked by a suitably qualified tradesman.	

DRAINAGE	Repair Category: 1
No defects noted to the drainage at the time of inspection.	

FIRE, SMOKE AND BURGLAR ALARMSRepair Category: **2**

Smoke detectors present in the hallway and sitting room, heat detector in the kitchen. Not tested.

CONDITION SUMMARY

Element	Cat	
Structural movement	1	
Dampness, rot and infestation	1	
Chimney stacks	1	Category 1 — No immediate action or repair is needed.
Roofing including roof space	1	
Rainwater fittings	1	
Main walls	1	Category 2 — Repair or replacement requiring significant expenditure.
Windows, external doors and joinery	1	
External decorations	1	
Conservatories and porches	n/a	Category 3 — Urgent repairs or replacement are needed now.
Communal areas	1	
Garages and permanent outbuildings	1	
Outside areas and boundaries	n/a	Not applicable — this element is not present at the property.
Ceilings	1	
Internal walls	1	
Floors including sub-floors	1	
Internal joinery and kitchen fittings	1	
Chimney breasts and fireplaces	n/a	
Internal decoration	2	
Cellars	n/a	
Electricity	1	
Gas	n/a	
Water, plumbing and bathroom fittings	1	
Heating and hot water	1	
Drainage	1	
Fire, smoke and burglar alarms	2	

SECTION 3 — ACCESSIBILITY INFORMATION

This section gives information about the accessibility of the property.

Which floor(s) does the accommodation occupy?	First floor
Are there three steps or fewer to the main entrance door?	Yes
Is there a lift to the main entrance?	No
Are all door openings at least 750 mm wide?	No
Is there a toilet on the same level as the main living room and kitchen?	Yes
Is there a toilet on the same level as all bedrooms?	Yes
Are all the rooms on the same level with no internal steps or stairs?	Yes
Is there unrestricted parking within 25 metres of the main entrance?	No

Three steps or fewer to a main entrance door of the property: In flatted developments the 'main entrance' would be the flat's own entrance door, not the external door to the communal stair. The 'three steps or fewer' are counted from external ground level to the flat's entrance door. Where a lift is present, the count is based on the number of steps climbed when using the lift.

Unrestricted parking within 25 metres: For this purpose, 'Unrestricted parking' includes parking available by means of a parking permit. Restricted parking includes: parking that is subject to parking restrictions, as indicated by the presence of solid yellow, red or white lines at the edge of the road or by a parking control sign, parking meters or other coin-operated machines.

SECTION 4 — VALUATION AND CONVEYANCER ISSUES

This section highlights information that should be checked with a solicitor or licensed conveyancer. It also gives an opinion of market value and an estimated re-instatement cost for insurance purposes.

Valuation


I am of the opinion that the open market value of 1C Laing Street, Kirkwall, KW15 1NW, as inspected, is fairly stated at **£115,000**.

Estimated reinstatement cost for insurance purposes: **£200,000**.

Conveyancer Issues

The subject flat forms part of a tenement building with communal areas including the common stair and entrance. The conveyancer should confirm the title obligations and cost-sharing arrangements for maintenance and repair of these communal areas, including the roof, rainwater goods and common stair.

Report author: N J Coward
Address: The Office
Burgar House
Evie
KW17 2NJ



Signed:

Date of report: Friday, 25 September 2026

TERMS AND CONDITIONS

SINGLE SURVEY TERMS AND CONDITIONS (WITH MVR)

PART 1 – GENERAL

1.1 THE SURVEYORS

The Seller has engaged the Surveyors to provide the Single Survey Report and a generic Mortgage Valuation Report for Lending Purposes. The Seller has also engaged the Surveyors to provide an Energy Report in the format prescribed by the accredited Energy Company.

The Surveyors are authorised to provide a transcript or retype of the generic Mortgage Valuation Report on to Lender specific pro-forma. Transcript reports are commonly requested by Brokers and Lenders. The transcript report will be in the format required by the Lender but will contain the same information, inspection date and valuation figure as the generic Mortgage Valuation Report and the Single Survey. The Surveyors will decline any transcript request which requires the provision of information additional to the information in the Report and the generic Mortgage Valuation Report until the Seller has conditionally accepted an offer to purchase made in writing.

Once the Seller has conditionally accepted an offer to purchase made in writing, the Purchaser's lender or conveyancer may request that the Surveyors provide general comment on standard appropriate supplementary documentation. In the event of a significant amount of documentation being provided to the Surveyors, an additional fee may be incurred by the Purchaser. Any additional fee will be agreed in writing.

If information is provided to the Surveyors during the conveyancing process which materially affects the valuation stated in the Report and generic Mortgage Valuation Report, the Surveyors reserve the right to reconsider the valuation. Where the Surveyors require to amend the valuation in consequence of such information, they will issue an amended Report and generic Mortgage Valuation Report to the Seller. It is the responsibility of the Seller to ensure that the amended Report and generic Mortgage Valuation Report are transmitted to every prospective Purchaser.

The individual Surveyor will be a member of the Royal Institution of Chartered Surveyors who is competent to survey, value and report upon Residential Property.

If the Surveyors have had a previous business relationship within the past two years with the Seller or Seller's Agent or relative to the property, they will be obliged to indicate this by ticking the adjacent box.

The Surveyors have a written complaints handling procedure. This is available from the offices of the Surveyors at the address stated.

1.2 THE REPORT

The Surveyors will not provide an amended Report on the Property, except to correct factual inaccuracies.

The Report will identify the nature and source of information relied upon in its preparation.

The Surveyor shall provide a Market Value of the Property, unless the condition of the Property is such that it would be inappropriate to do so. A final decision on whether a loan will be granted rests with the Lender who may impose retentions in line with their lending criteria. The date of condition and value of the property will be the date of inspection.

Prior to 1 December 2008, Purchasers have normally obtained their own report from their chosen Surveyor. By contrast, a Single Survey is instructed by the Seller and made available to all potential Purchasers in expectation that the successful Purchaser will have relied upon it. The Royal Institution of Chartered Surveyors rules require disclosure of any potential conflict of interest when acting for the Seller and the Purchaser in the same transaction. The Single Survey may give rise to a conflict of interest and if this is of concern to any party they are advised to seek their own independent advice.

The Report and any expressions or assessments in it are not intended as advice to the Seller or Purchaser or any other person in relation to an asking price or any other sales or marketing decisions.

The Report is based solely on the Property and is not to be relied upon in any manner whatsoever when considering the valuation or condition of any other property.

If certain minor matters are mentioned in the Report it should not be assumed that the Property is free of other minor defects.

Neither the whole nor any part of the Report may be published in any way, reproduced or distributed by any party other than the Seller, prospective purchasers and the Purchaser and their respective professional advisers without the prior written consent of the Surveyors.

1.3 LIABILITY

The Report is prepared with the skill and care reasonably to be expected of a competent residential surveyor who is a member of the Royal Institution of Chartered Surveyors.

The Report is addressed to the Seller and was prepared in the expectation that it (or a complete copy) along with these Terms and Conditions (or a complete copy) would (or, as the case might be, would have been) be disclosed and delivered to:

- the Seller;
- any person(s) noting an interest in purchasing the Property from the Seller;
- any person(s) who make(s) (or on whose behalf is made) an offer to purchase the Property, whether or not that offer is accepted by the Seller;

- the Purchaser; and
- the professional advisers of any of these.

The Surveyors acknowledge that their duty of skill and care in relation to the Report is owed to the Seller and to the Purchaser. The Surveyors accept no responsibility or liability whatsoever in relation to the Report to persons other than the Seller and the Purchaser. The Seller and Purchaser should be aware that if a Lender seeks to rely on this Report they do so at their own risk. In particular, the Surveyors accept no responsibility or liability whatsoever to any Lender in relation to the Report. Any such Lender relies upon the Report entirely at their own risk.

1.4 GENERIC MORTGAGE VALUATION REPORT

The Surveyors undertake to the Seller that they will prepare a generic Mortgage Valuation Report, which will be issued along with the Single Survey. It is the responsibility of the Seller to ensure that the generic Mortgage Valuation Report is provided to every potential Purchaser.

1.5 TRANSCRIPT MORTGAGE VALUATION FOR LENDING PURPOSES

The Surveyors undertake that on being asked to do so by a prospective purchaser, or his/her professional advisor or Lender, they will prepare a Transcript Mortgage Valuation Report for Lending Purposes on terms and conditions to be agreed between the Surveyors and Lender and solely for the use of the Lender and upon which the Lender may rely. The decision as to whether finance will be provided is entirely a matter for the Lender. The Transcript Mortgage Valuation Report will be prepared from information contained in the Report and the generic Mortgage Valuation Report.

1.6 INTELLECTUAL PROPERTY

All intellectual property rights whatsoever (including copyright) in and to the Report, excluding the headings and rubrics, are the exclusive property of the Surveyors and shall remain their exclusive property unless they assign the same to any other party in writing.

1.7 PAYMENT

The Surveyors are entitled to refrain from delivering the Report to anyone until the fee and other charges for it notified to the Seller have been paid.

Additional fees will be charged for subsequent inspections and Reports.

1.8 CANCELLATION

The Seller will be entitled to cancel the inspection by notifying the Surveyor's office at any time before the day of the inspection.

The Surveyor will be entitled not to proceed with the inspection (and will so report promptly to the Seller) if after arriving at the property, the Surveyor concludes that it is of a type of construction of which the Surveyor has insufficient specialist knowledge to be able to provide the inspection satisfactorily. The Surveyor will also be entitled not to proceed if after arriving at the property, the Surveyor concludes that the property is

exempt under Part 3 of The Housing (Scotland) Act 2006 as detailed in the (Prescribed Documents) Regulations 2008. If there is a potential threat to their health or personal safety, the inspection may be postponed or cancelled, at the Surveyor's discretion.

In the case of cancellation or the inspection not proceeding, the Surveyor will refund any fees paid by the Seller for the inspection and Report, except for expenses reasonably incurred and any fee due in light of the final paragraph of this section.

In the case of cancellation by the Seller, for whatever reason, after the inspection has taken place but before a written report is issued, the Surveyor will be entitled to raise an invoice equivalent to 80% of the agreed fee.

1.9 PRECEDENCE

If there is any incompatibility between these Terms and Conditions and the Report, these Terms and Conditions take precedence.

1.10 DEFINITIONS

- the "Lender" is the party who has provided or intends or proposes to provide financial assistance to the Purchaser towards the purchase of the Property and in whose favour a standard security will be granted over the Property;
- the "Transcript Mortgage Valuation Report for Lending Purposes" means a separate report, prepared by the Surveyor, prepared from information in the Report and the generic Mortgage Valuation Report, but in a style and format required by the Lender. The Transcript Mortgage Valuation Report for Lending Purposes will be prepared with the skill and care reasonably to be expected from a surveyor who is a member of the Royal Institution of Chartered Surveyors and who is competent to survey, value and report on the Property;
- the "Generic Mortgage Valuation Report" means a separate report, prepared by the Surveyor from information in the Report but in the Surveyor's own format.
- the "Market Value" is the estimated amount for which a property should exchange on the date of valuation between a willing buyer and a willing seller in an arm's-length transaction after proper marketing wherein the parties had each acted knowledgeably, prudently and without compulsion;
- the "Property" is the property which forms the subject of the Report;
- the "Purchaser" is the person (or persons) who enters into a contract to buy the Property from the Seller;
- a "prospective Purchaser" is anyone considering buying the Property;
- the "Report" is the report, of the kind described in Part 2 of these Terms and Conditions and in the form set out in part 1 of Schedule 1 of the Housing (Scotland) Act 2006 (Prescribed Documents) Regulations 2008;
- the "Seller" is/are the proprietor(s) of the Property;
- the "Surveyor" is the author of the Report on the Property; and

- the "Surveyors" are the firm or company of which the Surveyor is an employee, director, member or partner (unless the Surveyor is not an employee, director, member or partner, when the "Surveyors" means the Surveyor) whose details are set out at the head of the Report.
- the "Energy Report" is the advice given by the accredited Energy Company, based on information collected by the Surveyor during the Inspection, and also includes an Energy Performance Certificate, in a Government approved format.

PART 2 – DESCRIPTION OF THE REPORT

2.1 THE SERVICE

The Single Survey is a Report by an independent Surveyor, prepared in an objective way regarding the condition and value of the Property on the day of the inspection, and who is a member of the Royal Institution of Chartered Surveyors. It includes an Energy Report as required by Statute and this is in the format of the accredited Energy Company. In addition, the Surveyor has agreed to supply a generic Mortgage Valuation Report.

2.2 THE INSPECTION

The Inspection is a general surface examination of those parts of the Property which are accessible: in other words, visible and readily available for examination from ground and floor levels, without risk of causing damage to the Property or injury to the Surveyor.

All references to visual inspection refer to an inspection from within the property at floor level and from ground level within the site and adjoining public areas, without the need to move any obstructions. Any references to left or right are taken facing the front of the property.

The Inspection is carried out with the Seller's permission, without causing damage to the building or contents. Furniture, stored items and insulation are not moved.

Unless identified in the report the Surveyor will assume that no harmful or hazardous materials have been used in the construction. The presence or possible consequences of any site contamination will not be researched.

The Surveyor will not carry out an asbestos inspection, and will not be acting as an asbestos inspector in completing a Single Survey of properties that may fall within the Control of Asbestos in the Workplace Regulations. In the case of flats it will be assumed that there is a duty holder, as defined in the Regulations, and that a Register of Asbestos and effective Management Plan is in place, which does not require any expenditure, or pose a significant risk to health. No enquiry of the duty holder will be made.

2.3 THE REPORT

The Report will be prepared by the Surveyor who carried out the property inspection and will describe various aspects of the property as defined by the headings of the

Single Survey report with the comments being general and unbiased. The report on the location, style and condition of the property, will be concise and will be restricted to matters that could have a material effect upon value and will omit items that, in the Surveyor's opinion, are not significant. If certain minor matters are mentioned, it should not be interpreted that the property is free of any other minor defects.

Throughout the Report, the following repair categories will be used to give an overall opinion of the state of repair and condition of the property.

2.3.1 Category 3: Urgent repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now.

2.3.2 Category 2: Repairs or replacement requiring future attention, but estimates are still advised.

2.3.3 Category 1: No immediate action or repair is needed.

WARNING: If left unattended, even for a relatively short period, Category 2 repairs can rapidly develop into more serious Category 3 repairs. The existence of Category 2 or Category 3 repairs may have an adverse effect on marketability, value and the sale price ultimately achieved for the property. This is particularly true during slow market conditions when the effect can be considerable.

Parts of the property, which cannot be seen or accessed, will not be reported upon and this will be stated. If the Surveyor suspects that a defect may exist within an unexposed area and which could have a material effect upon the value, he may recommend further investigation by specialist contractors.

2.4 SERVICES

Surveyors are not equipped or qualified to test the services and therefore no comment can be interpreted as implying that the design, installation and function of the services are in accordance/compliance with regulations, safety and efficiency expectations. However, comment is made where there is cause to suspect significant defects or shortcomings with the installations. No tests are made of any services or appliances.

2.5 ACCESSIBILITY

A section is included to help identify the basic information interested parties need to know to decide whether to view a property.

2.6 ENERGY REPORT

A section is included that makes provision for an Energy Report, relative to the property. The Surveyor will collect physical data from the property and provide such data in a format required by an accredited Energy Company. The Surveyor cannot of course accept liability for any advice given by the Energy Company.

2.7 VALUATION AND CONVEYANCER ISSUES

"Market Value" — The estimated amount for which a property should exchange on the date of valuation between a willing buyer and a willing seller in an arm's-length

transaction after proper marketing wherein the parties had each acted knowledgeably, prudently and without compulsion. In arriving at the opinion of the Market Value the Surveyor also makes various standard assumptions covering, for example, vacant possession; tenure and other legal considerations; contamination and hazardous materials; the condition of un-inspected parts; the right to use mains services; and the exclusion of curtains, carpets etc. from the valuation.

In the case of flats, the following further assumptions are made:

- There are rights of access and exit over all communal roadways, corridors, stairways etc. and to use communal grounds, parking areas, and other facilities;
- There are no particularly troublesome or unusual legal restrictions;
- There is no current dispute between the occupiers of the flats or any outstanding claims or losses; and the costs of repairs to the building are shared among the co-proprietors on an equitable basis.

Any additional assumption, or any found not to apply, is reported.

"Re-instatement cost" is an estimate for insurance purposes of the current cost of rebuilding the Property in its present form unless otherwise stated. This includes the cost of rebuilding the garage and permanent outbuildings, site clearance and professional fees, but excludes VAT (except on the fees).

Sellers or prospective Purchasers may consider it prudent to instruct a reinspection and revaluation after a period of 12 weeks (or sooner if appropriate) to reflect changing circumstances in the market and/or in the physical condition of the Property.

TERMS AND CONDITIONS – WITH MVR – SEPTEMBER 2009



1C Laing Street
Kirkwall
KW15 1NW

Property: 1C Laing Street, Kirkwall, KW15 1NW

Date Inspected: 22 September 2026

DESCRIPTION: Flat

Type: Flat Floor Area 53 sq metres

Accommodation:

Livingroom	Bedrooms	Kitchen	Bathrooms	WC	Other
1	1	1	1	0	0

Neighbourhood: The property lies within Kirkwall town centre, on the corner of Albert Street and Laing Street.

Age: Circa 226 years (built circa 1800).

Construction

Walls: Random rubble masonry walls with cast concrete skewes at the wallhead. Exposed semi-dressed stone to the front (Albert Street) elevation, cement pointed. Rear elevation dashed.

Roof: Welsh slate roof.

Services: Mains electricity and water connected. Mains drainage. No mains gas supply (none in Orkney).

Heating: No central heating. Night storage heaters to the sitting room and bedroom, electric blow heater to the bathroom.

Valuation and Market Comment

In its present condition and with the current state of the property market my valuation of the property is **£115,000**

The rebuilding cost for insurance purposes is **£200,000**

YOU WILL NEED ALL RELEVANT ESTIMATES AND REPORTS NOW

Matters affecting Value

Lower Flat, 1C Laing Street is a mid-floor flat in a 3 storey semi-detached tenement situated in the centre of the commercial area of Kirkwall. It is immediately above a branch of Santander.

Access to the property is through a communal courtyard and staircase.


The property stands in generally satisfactory, though tired, condition.

Matters for your Conveyancer

The extent of common repair and maintenance responsibility for the communal stair and entrance should be confirmed via title deeds.

Tenure : Absolute Ownership

Valuer: N J Coward
The Office
Burgar House
Evie



Signed:

Telephone 07732614493

Date of Valuation 22 September 2026

GUIDANCE NOTES

You have chosen a valuation report which is a limited inspection of the property highlighting only those items which I consider will materially affect value. It is prepared on instructions from yourself in accordance with the RICS Specification for Residential Mortgage Valuations a copy of which is available on request.

I cannot see through solids or see things that are hidden by wall and floor coverings. I will not move furniture or obstructions inside or outside, lift carpets, crawl under floors, climb ladders outside or go on roofs or fully enter roof spaces. I will look at the outside of the property from the garden and adjacent public areas.

Services including central heating system have not been tested.

You still have the option to request a more detailed report and I will be pleased to help you with this.

I have assumed the property information supplied is correct although your conveyancer should verify this.

If you wish to discuss any aspect of this report please contact me.

Do not forget to read the Advice For Clients section — it is important.

ADVICE FOR CLIENTS

Problems may have been highlighted and you may require reports and estimates. When obtaining these I would suggest you use a reputable contractor with an insurance backed guarantee and who is preferably a member of a trade organisation.

When reports and estimates are being obtained, your contractor may go further than the valuer for example lifting carpets and floorboards, and may reveal more serious problems.

To make sure you are properly covered get your conveyancer to check on existing guarantees and maintenance contracts for example central heating, damp and timber treatments. Please note I have not tested services.

I may have mentioned "Legal requirements or consents". This means such things as planning and building regulation permissions, listed building consent, party wall issues, health and safety matters, freeholder consents, title restrictions, road and sewer bonds etc. Your conveyancer can advise you further.

Information and testing of electrical systems can be obtained from a qualified member of N.I.C.E.I.C. telephone 0207 5827746 or the ECA 0207 313 4800.

Information and testing of gas appliances can be obtained from a CORGI registered specialist, for names telephone 0800 371782.

Advice on asbestos can be obtained from the local Environmental Health Department of your local authority. For advice on contractors who can remove asbestos telephone the Asbestos Removal Contractors Association on 01283 531126.

If I have mentioned radon or high voltage electrical supply apparatus, advice can be obtained from the National Radiological Protection Board telephone 0800 614529. If I have mentioned contaminated land make sure your conveyancer checks with the local authority what steps have been taken either by the local authority or anyone else to deal with any possible contamination.

Remember, if you are buying a property you need all relevant estimates and reports before you agree to buy and I would recommend they are in your name.

For further advice about matters in this valuation contact the valuer who has carried it out.

Energy Performance Certificate (EPC)

Scotland

Dwellings

LOWER FLAT , 1C LAING STREET, KIRKWALL, KW15 1NW

Dwelling type: Mid-floor flat
Date of assessment: 03 December 2024
Date of certificate: 16 December 2024
Total floor area: 47 m²
Primary Energy Indicator: 747 kWh/m²/year

Reference number: 0370-1925-0202-1874-0204
Type of assessment: RdSAP, existing dwelling
Approved Organisation: Elmhurst
Main heating and fuel: Electric storage heaters


You can use this document to:

- Compare current ratings of properties to see which are more energy efficient and environmentally friendly
- Find out how to save energy and money and also reduce CO₂ emissions by improving your home

Estimated energy costs for your home for 3 years*	£5,667	See your recommendations report for more information
Over 3 years you could save*	£2,433	

* based upon the cost of energy for heating, hot water, lighting and ventilation, calculated using standard assumptions

Very energy efficient - lower running costs



Not energy efficient - higher running costs

Current	Potential
47	61


Energy Efficiency Rating

This graph shows the current efficiency of your home, taking into account both energy efficiency and fuel costs. The higher this rating, the lower your fuel bills are likely to be.

Your current rating is **band E (47)**. The average rating for EPCs in Scotland is **band D (61)**.

The potential rating shows the effect of undertaking all of the improvement measures listed within your recommendations report.

Very environmentally friendly - lower CO₂ emissions



Not environmentally friendly - higher CO₂ emissions

Current	Potential
33	59

Environmental Impact (CO₂) Rating

This graph shows the effect of your home on the environment in terms of carbon dioxide (CO₂) emissions. The higher the rating, the less impact it has on the environment.

Your current rating is **band F (33)**. The average rating for EPCs in Scotland is **band D (59)**.

The potential rating shows the effect of undertaking all of the improvement measures listed within your recommendations report.

Top actions you can take to save money and make your home more efficient

Recommended measures	Indicative cost	Typical savings over 3 years
1 Internal wall insulation	£4,000 - £14,000	£1185.00
2 Add additional 80 mm jacket to hot water cylinder	£15 - £30	£105.00
3 High heat retention storage heaters	£800 - £1,200	£1146.00

A full list of recommended improvement measures for your home, together with more information on potential cost and savings and advice to help you carry out improvements can be found in your recommendations report.

To find out more about the recommended measures and other actions you could take today to stop wasting energy and money, visit [greenerscotland.org](https://www.greenerscotland.org) or contact Home Energy Scotland on 0808 808 2282.

THIS PAGE IS THE ENERGY PERFORMANCE CERTIFICATE WHICH MUST BE AFFIXED TO THE DWELLING AND NOT BE REMOVED UNLESS IT IS REPLACED WITH AN UPDATED CERTIFICATE

Summary of the energy performance related features of this home

This table sets out the results of the survey which lists the current energy-related features of this home. Each element is assessed by the national calculation methodology; 1 star = very poor (least efficient), 2 stars = poor, 3 stars = average, 4 stars = good and 5 stars = very good (most efficient). The assessment does not take into consideration the condition of an element and how well it is working. 'Assumed' means that the insulation could not be inspected and an assumption has been made in the methodology, based on age and type of construction.

Element	Description	Energy Efficiency	Environmental
Walls	Sandstone or limestone, as built, no insulation (assumed)	★★☆☆☆	★★☆☆☆
	Timber frame, as built, no insulation (assumed)	★★☆☆☆	★★☆☆☆
Roof	(another dwelling above)	—	—
Floor	(other premises below)	—	—
Windows	Fully double glazed	★★★★☆☆	★★★★☆☆
Main heating	Electric storage heaters	★★★★☆☆	★☆☆☆☆
Main heating controls	Manual charge control	★★☆☆☆☆	★★☆☆☆☆
Secondary heating	Portable electric heaters (assumed)	—	—
Hot water	Electric immersion, off-peak	★☆☆☆☆	★★☆☆☆
Lighting	Low energy lighting in all fixed outlets	★★★★★★	★★★★★★

The energy efficiency rating of your home

Your Energy Efficiency Rating is calculated using the standard UK methodology, RdSAP. This calculates energy used for heating, hot water, lighting and ventilation and then applies fuel costs to that energy use to give an overall rating for your home. The rating is given on a scale of 1 to 100. Other than the cost of fuel for electrical appliances and for cooking, a building with a rating of 100 would cost almost nothing to run.

As we all use our homes in different ways, the energy rating is calculated using standard occupancy assumptions which may be different from the way you use it. The rating also uses national weather information to allow comparison between buildings in different parts of Scotland. However, to make information more relevant to your home, local weather data is used to calculate your energy use, CO₂ emissions, running costs and the savings possible from making improvements.

The impact of your home on the environment

One of the biggest contributors to global warming is carbon dioxide. The energy we use for heating, lighting and power in our homes produces over a quarter of the UK's carbon dioxide emissions. Different fuels produce different amounts of carbon dioxide for every kilowatt hour (kWh) of energy used. The Environmental Impact Rating of your home is calculated by applying these 'carbon factors' for the fuels you use to your overall energy use.

The calculated emissions for your home are 126 kg CO₂/m²/yr.

The average Scottish household produces about 6 tonnes of carbon dioxide every year. Based on this assessment, heating and lighting this home currently produces approximately 5.9 tonnes of carbon dioxide every year. Adopting recommendations in this report can reduce emissions and protect the environment. If you were to install all of these recommendations this could reduce emissions by 2.0 tonnes per year. You could reduce emissions even more by switching to renewable energy sources.



Estimated energy costs for this home

	Current energy costs	Potential energy costs	Potential future savings
Heating	£4,260 over 3 years	£2,367 over 3 years	
Hot water	£1,218 over 3 years	£678 over 3 years	
Lighting	£189 over 3 years	£189 over 3 years	
Totals	£5,667	£3,234	

These figures show how much the average household would spend in this property for heating, lighting and hot water. This excludes energy use for running appliances such as TVs, computers and cookers, and the benefits of any electricity generated by this home (for example, from photovoltaic panels). The potential savings in energy costs show the effect of undertaking all of the recommended measures listed below.

Recommendations for improvement

The measures below will improve the energy and environmental performance of this dwelling. The performance ratings after improvements listed below are cumulative; that is, they assume the improvements have been installed in the order that they appear in the table. Further information about the recommended measures and other simple actions to take today to save money is available from the Home Energy Scotland hotline which can be contacted on 0808 808 2282. Before carrying out work, make sure that the appropriate permissions are obtained, where necessary. This may include permission from a landlord (if you are a tenant) or the need to get a Building Warrant for certain types of work.

Recommended measures	Indicative cost	Typical saving per year	Rating after improvement	
			Energy	Environment
1 Internal wall insulation	£4,000 - £14,000	£395		
2 Add additional 80 mm jacket to hot water cylinder	£15 - £30	£35		
3 High heat retention storage heaters and dual immersion cylinder	£800 - £1,200	£382		

Alternative measures

There are alternative improvement measures which you could also consider for your home. It would be advisable to seek further advice and illustration of the benefits and costs of such measures.

- Biomass boiler (Exempted Appliance if in Smoke Control Area)
- Air or ground source heat pump

Choosing the right improvement package

For free and impartial advice on choosing suitable measures for your property, contact the Home Energy Scotland hotline on 0808 808 2282 or go to www.greenerscotland.org.

About the recommended measures to improve your home's performance rating

This section offers additional information and advice on the recommended improvement measures for your home

1 Internal wall insulation

Internal wall insulation involves adding a layer of insulation to the inside surface of the external walls, which reduces heat loss and lowers fuel bills. As it is more expensive than cavity wall insulation it is only recommended for walls without a cavity, or where for technical reasons a cavity cannot be filled. Internal insulation, known as dry-lining, is where a layer of insulation is fixed to the inside surface of external walls; this type of insulation is best applied when rooms require redecorating. Further information can be obtained from the National Insulation Association (www.nationalinsulationassociation.org.uk).

2 Hot water cylinder insulation

Increasing the thickness of existing insulation by adding an 80 mm cylinder jacket around the hot water cylinder will help maintain the water at the required temperature; this will reduce the amount of energy used and lower fuel bills. The jacket should be fitted over the top of the existing foam insulation and over any thermostat clamped to the cylinder. Hot water pipes from the hot water cylinder should also be insulated, using pre-formed pipe insulation of up to 50 mm thickness, or to suit the space available, for as far as they can be accessed to reduce losses in summer. All these materials can be purchased from DIY stores and installed by a competent DIY enthusiast.

3 High heat retention storage heaters

Modern storage heaters have better insulation and are easier to control than the older type in this property. Ask for a quotation for new, high heat retention heaters with automatic charge and output controls. A dual-immersion cylinder, which can be installed at the same time, will provide cheaper hot water than the system currently installed. Installations should be in accordance with the current regulations covering electrical wiring. Ask the heating engineer to explain the options, which might also include switching to other forms of electric heating.

Low and zero carbon energy sources

Low and zero carbon (LZC) energy sources are sources of energy that release either very little or no carbon dioxide into the atmosphere when they are used. Installing these sources may help reduce energy bills as well as cutting carbon.

LZC energy sources present: There are none provided for this home

Your home's heat demand

In this section, you can see how much energy you might need to heat your home and provide hot water. These are estimates showing how an average household uses energy. These estimates may not reflect your actual energy use, which could be higher or lower. You might spend more money on heating and hot water if your house is less energy efficient. The table below shows the potential benefit of having your loft and walls insulated. Visit <https://energysavingtrust.org.uk/energy-at-home> for more information.

Heat demand	Existing dwelling	Impact of loft insulation	Impact of cavity wall insulation	Impact of solid wall insulation
Space heating (kWh per year)	9,429	N/A	N/A	(2,622)
Water heating (kWh per year)	1,791			

Addendum

This dwelling has stone walls and may be exposed to wind driven rain and so requires further investigation to establish whether these walls are of cavity construction and to determine which type of wall insulation is best suited.

About this document

This Recommendations Report and the accompanying Energy Performance Certificate are valid for a maximum of ten years. These documents cease to be valid where superseded by a more recent assessment of the same building carried out by a member of an Approved Organisation.

The Energy Performance Certificate and this Recommendations Report for this building were produced following an energy assessment undertaken by an assessor accredited by Elmhurst (www.elmhurstenergy.co.uk), an Approved Organisation Appointed by Scottish Ministers. The certificate has been produced under the Energy Performance of Buildings (Scotland) Regulations 2008 from data lodged to the Scottish EPC register. You can verify the validity of this document by visiting www.scottishepcregister.org.uk and entering the report reference number (RRN) printed at the top of this page.

Assessor's name:	Mr. Christopher Park
Assessor membership number:	EES/021836
Company name/trading name:	S J Omand
Address:	14 Victoria Street Orkney Kirkwall KW15 1DW
Phone number:	01856 876215
Email address:	chris.park@sjomand.co.uk
Related party disclosure:	No related party

If you have any concerns regarding the content of this report or the service provided by your assessor you should in the first instance raise these matters with your assessor and with the Approved Organisation to which they belong. All Approved Organisations are required to publish their complaints and disciplinary procedures and details can be found online at the web address given above.

Use of this energy performance information

Once lodged by your EPC assessor, this Energy Performance Certificate and Recommendations Report are available to view online at www.scottishepcregister.org.uk, with the facility to search for any single record by entering the property address. This gives everyone access to any current, valid EPC except where a property has a Green Deal Plan, in which case the report reference number (RRN) must first be provided. The energy performance data in these documents, together with other building information gathered during the assessment is held on the Scottish EPC Register and is available to authorised recipients, including organisations delivering energy efficiency and carbon reduction initiatives on behalf of the Scottish and UK governments. A range of data from all assessments undertaken in Scotland is also published periodically by the Scottish Government. Further information on these matters and on Energy Performance Certificates in general, can be found at www.gov.scot/epc.

Advice and support to improve this property

There is support available, which could help you carry out some of the improvements recommended for this property on page 3 and stop wasting energy and money. For more information, visit [greener-scotland.org](https://www.greener-scotland.org) or contact Home Energy Scotland on 0808 808 2282.

Home Energy Scotland's independent and expert advisors can offer free and impartial advice on all aspects of energy efficiency, renewable energy and more.

HOMEENERGYSCOTLAND.ORG
0808 808 2282
FUNDED BY THE SCOTTISH GOVERNMENT



property questionnaire

Property Address	
Seller(s)	(Marketed by K A
Completion date of Property Questionnaire	27-Sep-2026

Note for sellers

- Please complete this form carefully. It is important your answers are correct.
- The information in your answers will help ensure that the sale of your house goes smoothly. Please answer each question with as much detailed information as you can.
- If anything changes after you fill in this questionnaire but before the date of entry for the sale of your house, tell you solicitor or estate agent immediately.

Information to be given to prospective buyer(s)

1.	Length of Ownership
	How long have you owned the property? 9 months
2.	Council Tax
	Which Council Tax band is your property in? A ☒ B ☐ C ☐ D ☐ E ☐ F ☐ G ☐ H ☐
3.	Parking
	What are the arrangements for parking at your property? (Please tick all that apply) Garage ☐ Allocated parking space ☐ Driveway ☐ On street ☐ Resident Permit ☐ Metered parking ☐ Shared parking ☐ Other (please specify) No parking

property questionnaire

4.	Conservation area	
	Is your property in a designated Conservation Area (that is an area of special architectural or historical interest, the character or appearance of which it is desirable to preserve or enhance)?	Don't know
5.	Listed buildings	
	Is your property a Listed Building, or contained within one (that is a building recognised and approved as being of special architectural or historical interest)?	Don't know
6.	Alterations/Additions/Extensions	
a.	(i) During your time in the property, have you carried out any structural alterations, additions or extensions (for example provision of an extra bath/shower room, toilet or bedroom)? <u>If you have answered yes</u>, please describe below the changes which you have made: (ii) Did you obtain planning permission, building warrant, completion certificate and other consents for this work? <u>If you have answered yes</u>, the relevant documents will be needed by the purchaser and you should give them to your solicitor as soon as possible for checking. If you do not have the documents yourself, please note below who has these documents and your solicitor or estate agent will arrange to obtain them.	No
b.	Have you had replacement windows, doors, patio doors or double-glazing installed in your property? If you have answered yes, please answer the three questions below: (i) Were the replacements the same shape and type as the ones you replaced? (ii) Did this work involve any changes to the window or door openings? (iii) Please describe the changes made to the windows doors, or patio doors (with approximate dates when the work was completed):	No

property questionnaire

7.	Central heating	
	Is there a central heating system in your property? (Note: a partial central heating system is one which does not heat all the main rooms of the property — the main living room, the bedroom(s), the hall and the bathroom). <u>If you have answered yes or partial</u> – what kind of central heating is there? (examples: gas-fired, solid fuel, electric storage heating, gas-warm air). If you have answered yes, please answer the three questions below:	Yes
	(i) When was your central heating system or partial central heating system installed? (ii) Do you have a maintenance contract for the central heating system? If you have answered yes, please give details of the company with which you have a maintenance contract: (iii) When was your maintenance agreement last renewed? (Please provide the month and year).	
8.	Energy Performance Certificate	
	Does your property have an Energy Performance Certificate, which is less than 10 years old?	Yes
9.	Issues that may have affected your property	
a.	Has there been any storm, flood, fire or other structural damage to your property while you have owned it? <u>If you have answered yes</u>, is the damage the subject of any outstanding insurance claim?	No

b.	Are you aware of the existence of asbestos in your property? <u>If you have answered yes</u>, please give details:	No																								
10.	Services																									
a.	Please tick which services are connected to your property and give details of the supplier: <table border="1" data-bbox="172 633 1182 1350"> <thead> <tr> <th>Services</th> <th>Connected</th> <th>Supplier</th> </tr> </thead> <tbody> <tr> <td>Gas or liquid petroleum gas</td> <td>☐</td> <td> </td> </tr> <tr> <td>Water mains or private water supply</td> <td>☒</td> <td> I don't know </td> </tr> <tr> <td>Electricity</td> <td>☒</td> <td> Octopus Energy </td> </tr> <tr> <td>Mains drainage</td> <td>☒</td> <td> I don't know </td> </tr> <tr> <td>Telephone</td> <td>☐</td> <td> </td> </tr> <tr> <td>Cable TV or satellite</td> <td>☐</td> <td> </td> </tr> <tr> <td>Broadband</td> <td>☒</td> <td> Sky </td> </tr> </tbody> </table>	Services	Connected	Supplier	Gas or liquid petroleum gas	☐		Water mains or private water supply	☒	I don't know	Electricity	☒	Octopus Energy	Mains drainage	☒	I don't know	Telephone	☐		Cable TV or satellite	☐		Broadband	☒	Sky	
Services	Connected	Supplier																								
Gas or liquid petroleum gas	☐																									
Water mains or private water supply	☒	I don't know																								
Electricity	☒	Octopus Energy																								
Mains drainage	☒	I don't know																								
Telephone	☐																									
Cable TV or satellite	☐																									
Broadband	☒	Sky																								
b.	Is there a septic tank system at your property? <u>If you have answered yes</u>, please answer the two questions below: (i) Do you have appropriate consents for the discharge from your septic tank? (ii) Do you have a maintenance contract for your septic tank? <u>If you have answered yes</u>, please give details of the company with which you have a maintenance contract:	No																								

property questionnaire

11.	Responsibilities for shared or common areas	
a.	Are you aware of any responsibility to contribute to the cost of anything used jointly, such as the repair of a shared drive, private road, boundary, or garden area? <u>If you have answered yes</u>, please give details:	Yes
b.	Is there a responsibility to contribute to repair and maintenance of the roof, common stairwell or other common areas? <u>If you have answered yes</u>, please give details:	Yes
c.	Has there been any major repair or replacement of any part of the roof during the time you have owned the property?	No
d.	Do you have the right to walk over any of your neighbours' property - for example to put out your rubbish bin or to maintain your boundaries? <u>If you have answered yes</u>, please give details:	Yes
e.	As far as you are aware, do any of your neighbours have the right to walk over your property, for example to put out their rubbish bin or to maintain their boundaries? <u>If you have answered yes</u>, please give details:	Yes

property questionnaire

f.	As far as you are aware, is there a public right of way across any part of your property (public right of way is a way over privately-owned)? <u>If you have answered yes</u>, please give details:	No
12.	Charges associated with your property	
a.	Is there a factor or property manager for your property? <u>If you have answered yes</u>, please provide the name and address, and give details of any deposit held and approximate charges:	No
b.	Is there a common buildings insurance policy? <u>If you have answered yes</u>, is the cost of the insurance included in your monthly/annual factor's charges?	Yes
c.	Please give details of any other charges you have to pay on a regular basis for the upkeep of common areas or repair works, for example to a residents' association, or maintenance or stair fund.	

property questionnaire

13.	Specialist works	
a.	As far as you are aware, has treatment of dry rot, wet rot, damp or any other specialist work ever been carried out to your property? If you have answered yes, please say what the repairs were for, whether you carried out the repairs (and when) or if they were done before you bought the property:	No
b.	As far as you were aware, has any preventative work for dry rot, wet rot, or damp, ever been carried out to your property? <u>If you have answered yes</u>, please give details:	No
c.	<u>If you have answered yes</u> to 13(a) or (b), do you have any guarantees relating to this work? <u>If you have answered yes</u> these guarantees will be needed by the purchaser and should be given to your solicitor as soon as possible for checking. If you do not have them yourself <u>please write below who has these documents</u> and your solicitor or estate agent will arrange for them to be obtained. You will also need to provide a description of the work carried out. This may be shown in the original estimate. Guarantees are held by:	

14.	Guarantees	
a.	Are there any guarantees or warranties for any of the following: (i) Electrical work (ii) Roofing (iii) Central heating (iv) National House Building Council (NHBC) (v) Damp course (vi) Any other work or installations (for example, cavity wall insulation, underpinning, indemnity policy)	Don't know Don't know Don't know Don't know Don't know Don't know
b.	If you have answered yes or 'with title deeds', please give details of the work or installations to which the guarantee(s) relate(s):	
c.	Are there any outstanding claims under any of the guarantees listed above? <u>If you have answered yes</u>, please give details:	No
15.	Boundaries	
	So far as you are aware, has any boundary of your property been moved in the last 10 years? <u>If you have answered yes</u>, please give details:	No

property questionnaire

16.	Notices that affect your property	
	In the past three years have you ever received a notice:	
a.	advising that the owner of a neighbouring property has made a planning application?	No
b.	that affects your property in some other way?	No
c.	that requires you to do any maintenance, repairs or improvements to your property?	No
	<u>If you have answered yes to any of a–c above</u> , please give the notices to your solicitor or estate agent, including any notices which arrive at any time before the date of entry of the purchaser of your property.	

Declaration by the seller(s)/or other authorised body or person(s)

I/We confirm that the information in this form is true and correct to the best of my/our knowledge and belief.

Signature(s):

Signature:



(Sep 27, 2026 16:58:13 GMT+1)

Email:



Sep 27, 2026

Date:

Blank original PQ Template

Final Audit Report

2026-09-27

Created:	2026-09-27
By:	Nick Coward (nick@njcoward.co.uk)
Status:	Filled
Transaction ID:	CBJCHBCAABAAp1c_zpVtuBN3qKpf4Px-jOtDx1m0_0KE

"Blank original PQ Template" History

-  Web Form created by Nick Coward (nick@njcoward.co.uk)
2025-01-19 - 6:54:41 AM GMT
-  Web Form filled in by [REDACTED]
2026-09-27 - 3:58:14 PM GMT
-  Email verification link emailed to [REDACTED]
2026-09-27 - 3:58:17 PM GMT
-  Email viewed by [REDACTED]
2026-09-27 - 3:58:38 PM GMT
-  Submission verified by [REDACTED]
2026-09-27 - 3:58:38 PM GMT
-  Agreement completed.
2026-09-27 - 3:58:38 PM GMT

